

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR

DAVIS STUART INC, WV3301303

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 8/1/2021 and 8/31/2021, we failed to submit the required samples as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
27, MONITORING, ROUTINE (DBP), MAJOR Failure to Report Required Chlorine Residual With a Coliform Sample Result	8/1/2021 to 8/31/2021

What happened? What is being done? (Describe corrective action)

Davis Stuart collected a water sample on: 8/9/2021. The sample was mailed to the WVDHHR/OEHS Laboratory Services for analysis and found to be Absent of Total Coliforms. The Total Chlorine measured for that test was 1.2mg/L. Unfortunately through an oversight on my part I forgot to write this chlorine residual on the test form, hence the violation. Davis Stuart's water employees will review documentation prior to sending it to the WVDHHR/OEHS for compliance purposes.

For more information, please contact Thomas M. Falls at 304-646-1148
(Contact name) (Phone number)
or 163 Cottage Drive Lewisburg, WV 24901
(Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **DAVIS STUART INC**

State Water System ID #: WV3301303

Date Distributed: 1/10/2022